



Barr River hydro scheme

Monthly report – September 2021

1 Summary

A month of completion and optimisation. Intake 3 and the minor intakes were connected in the first half of the month. Chamber levels and the control intake were adjusted throughout the second half of month with various configurations tested to determine the optimal arrangement. River level to power relationship has been implemented but is still being tuned, so the relationship is not ideal. All operating parameters (temperatures, vibration etc) are within expected ranges.


2 Monthly generation & revenue

| Parameter | Value |
|---|----------|
| Actual generation (FIT meter), kWh | 356,893 |
| Average generation in month, kWh | 356,893 |
| Forecast generation in month (P50), kWh | 358,000 |
| Actual relative to forecast | 99.7% |
| Rainfall relative to 1981-2010 average by month | 79.0% |
| Calculated generation ¹ kWh | 361,406 |
| Actual relative to calculated generation, kWh | - 4,513 |
| Actual relative to calculated generation, % | -1.2% |
| Approximate revenue in month | £ 59,530 |

¹Calculated generation is based on river level data and seeks to establish the expected generation with no performance issues. The expected power and energy calculations are being calibrated and will be refined over the coming months as more data is gathered.

| Export meter | Value |
|-----------------------------|--------------|
| Export, kWh | Data awaited |
| Variance to generation, kWh | Data awaited |
| Variance to generation, % | Data awaited |

3 System reporting



3.1 Scheme anomalies to calculated generation

| Date/time | Details | Action required |
|-------------------|--|---|
| 1/9/21 | Power off while SSEC on site and Perspex panel is fitted in RG1. | None |
| 2/9/21 – 5/9/21 | SCADA crashed. Water level low throughout, no operation. | SCADA restarted by Nick. |
| 9/9/21 | Grid outage. | None |
| 10/9/21 – 12/9/21 | Plant running but intake 2-3 not yet connected. | None |
| 14/9/21 | Power higher than expected (sensor resolution/rounding). | None |
| 16/9/21 – 17/9/21 | Intake 2 spilling. | Review control levels and which is master intake. |
| 19/9/21 | Intake 2 spilling. | Review control levels and which is master intake. |
| 22/9/21 | Grid outage, transformer breaker tripped. | Breaker reset by John. |
| 23/9/21 | Power higher than expected. Grid outage, transformer breaker tripped. | Breaker reset by Angus. |
| 25/9/21 | Power less than expected, power vs river level relationship 'in training'. | Review power vs. river level relationship when more data available. |
| 27/9/21, 28/9/21 | Power higher than expected. | None |
| 30/9/21 | Sensor offsets changed – power vs. river level relationship changed. | Update power vs. river level relationship to accommodate offset. |

3.2 Other system events

| Date/time | Details | Action required |
|------------------|--|-----------------|
| 2/9/21 – 14/9/21 | MNx intakes connected. | None |
| 13/9/21 | Intake 3 connected. | None |
| 20/9/21 | Master intake changed from intake 1 to 2. | None |
| 30/9/21 | Sensor offsets changed to change order on SCADA. | None |

3.3 Head loss

| Target head loss at full power | Current head loss at full power | Status |
|--------------------------------|---------------------------------|---|
| 14.5m | 11.5m | Better than specified (as expected for a new pipeline). |

3.4 Temperatures


| Parameter | Temperature at or near full power, °C | Alert level, °C | Parameter | Temperature at or near full power, °C | Alert level, °C |
|-------------------------|---------------------------------------|-----------------|---------------------|---------------------------------------|-----------------|
| Generator DE bearing | 36 | 85 | Generator winding 1 | 61 | 145 |
| Generator NDE bearing 1 | 37 | 85 | Generator winding 2 | 59 | 145 |
| Generator NDE bearing 2 | 41 | 85 | Generator winding 3 | 63 | 145 |
| Turbine room | 17 | 30 | Power cabinet (RG1) | 30 | 42 |

4 Recommended and ongoing actions

| Action | Responsibility | Status |
|---|----------------|---|
| Commissioning/testing to be completed when sufficient water available | CINK | Ongoing |
| Scheme operation to be reviewed when sufficient water available | GHC | Largely completed, chamber level control still under review |
| Modify generator/transformer breaker settings so that generator breaker trips first | GHC | Completed (29/9/21) |

5 Rainfall

| | |
|--|-----|
| Rainfall this month (rain gauge), mm | 178 |
| Western Scotland rainfall in month with respect to 1981-2010 long term average | 79% |



6 Scheme annual performance summary

| 2021 | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | Year to date |
|---|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|---------|--------------|
| Actual generation kWh | | | | | | | 1,463 | 91,714 | 356,893 | | | | 451,887 |
| Average generation since commissioning | | | | | | | 1,463 | 91,714 | 356,893 | | | | 451,887 |
| Forecast generation (P50) | 783,000 | 655,000 | 592,000 | 318,000 | 186,000 | 176,000 | 174,000 | 237,000 | 358,000 | 584,000 | 634,000 | 659,000 | 769,000 |
| Variance to forecast | | | | | | | 0.8% | 38.7% | 99.7% | | | | 58.8% |
| Rainfall relative to 1981-2010 average by month | | | | | | | 37.0% | 69.0% | 79.0% | | | | 61.7% |
| Calculated generation kWh | | | | | | | | 91,458 | 361,406 | | | | 452,864 |
| Variance to calculated generation kWh | - | - | - | - | - | 0 | 0 | 256 | -4,513 | - | - | - | -2,440 |
| Variance to calculated generation % | | | | | | +0.0% | +0.0% | +0.3% | -1.2% | | | | +0.3% |
| Approximate revenue | £- | £- | £- | £- | £- | £- | £186 | £12,546 | £59,530 | £- | £- | £- | £72,565 |
| Capacity factor (monthly) | | | | | | | 0.1% | 7.6% | 30.6% | | | | 12.8% |
| Industry wide RoR capacity factor | 30.8% | 39.3% | 45.0% | 14.6% | 20.0% | 6.5% | 5.6% | 15.2% | | | | | 22.1% |

